

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1429:120

Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Secutron, Div. of Digital Security Controls LTD, 3301 Langstaff Rd, Ontario Canada L4K4L2
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models MRI-DH200PL and MRI-DH200RPL duct smoke detector units. Models consist of a housing, relay, electrical components, sampling and exhaust tubes and a listed detector head. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as duct smoke detector housing units when used with listee's separately listed compatible fire alarm control units. Intended for use in HVAC systems having air velocities between 100 -4000 ft/min. Also suitable for use as a stand alone unit where permitted. Refer to listee's Installation Instruction Manual for details.

XLF: 3240-1209:155

09-25-03kk



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager